

**Subcommittee on Second Technical Memorandum for  
Allocation of Emission Allowances in Respect of Specified Licences**

	<b>Emission Allowances for Power Stations (Tonnes Per Year)</b>								
	Sulphur dioxide (SO <sub>2</sub> )			Nitrogen oxides (NO <sub>x</sub> )			Respirable Suspended Particulates (RSP)		
	2010 allowance	2010 actual *	2015 allowance	2010 allowance	2010 actual *	2015 allowance	2010 allowance	2010 actual *	2015 allowance
Lamma Power Station and extension (HEC)	9 370	3 553	6 780	15 890	7 364	10 020	470	176	300
Black Point Power Station (CLP)	8 617	128	1 440	14 612	1 378	4 140	433	50	110
Castle Peak Power Station (CLP)	7 135	9 981	4 260	12 099	11 520	13 390	358	522	420
Penny's Bay Gas Turbine Power Station (CLP)	2	0.003	2	2	0.46	2	1	0.01	1

\* The actual emission levels of each of the power stations are from January to September 2010, which are subject to change upon auditing and verification.