

**156 Contraventions in Government Facilities that were reported to the Chief Secretary's Committee / Policy Committee since 1999**

Item	Location	Nature of contravention	Date discovered	Date reported	Long-term Improvement Measures	Date of completion	Responsible Department / Works Agent	Notes
1.	Carpark of Lions nature Education Center, Tsiu Hang, Sai Kung	Noise of engines from excessive parked vehicles exceeding the noise limit stipulated in the relevant technical memorandum, contravening s13 of the NCO Cap 400	Dec 1998	Dec 1999	Provided noise abatement measures.	Apr 2000	AFCD/ArchSD	
2	Hei Ling Chau Addiction Treatment Centre	Wastewater discharged to stream, contravening s.8(1)(a) of the WPCO, Cap. 358	Nov 1989	Jan 1999	Constructed a new sewer for connecting to the future communal sewage treatment plant (STP).	Dec 2001	CSD/DSD	Interim: provided a temporary sewage treatment works
3	Hei Ling Chau Staff Quarters of CSD	Substandard effluent from STP, contravening s.17B(1) of WPC(G)R	1997	Jan 1999	Installed an UV disinfection system	Oct 2000	CSD/DSD	Interim: controlled residual chlorine dosage level
4	Hei Ling Chau Correctional Institution	Substandard effluent from STP, contravening s.17B(1) of WPC(G)R	1997	Jan 1999	Installed an UV disinfection system	Dec 2001	CSD/DSD	Interim: controlled residual chlorine dosage level
5	Sha Tsui Detention Centre, Lantau	Wastewater discharged to sea, contravening s.8(1)(a) of the WPCO, Cap. 358	Sep 1994	Jan 1999	Constructed a new sewer for discharge to Shek Pik STP.	Dec 2001	CSD/DSD	Interim: built a new soakaway to intercept part of wastewater discharge.
6	Lai Sun Correctional Institution, Hei Ling Chau	Wastewater discharged to stream, contravening s.8(1)(a) of the WPCO, Cap. 358	Nov 1989	Jan 1999	Installed a new STP	Dec 2001	CSD/DSD	Interim: provided a temporary sewage treatment works
7	Correctional Facilities at Pik UK including Pik Uk Correctional Institution and Pik UK Prison, Sai Kung	Substandard effluent from STP, contravening s.17B(1) of WPC(G)R	Sep 1991	Jan 1999	Installed 2 new STPs	Apr 2002	CSD/DSD	

**156 Contraventions in Government Facilities that were reported to the Chief Secretary's Committee / Policy Committee since 1999**

<b>Item</b>	<b>Location</b>	<b>Nature of contravention</b>	<b>Date discovered</b>	<b>Date reported</b>	<b>Long-term Improvement Measures</b>	<b>Date of completion</b>	<b>Responsible Department / Works Agent</b>	<b>Notes</b>
8	Tai Lam Centre for Women at Tai Lam Chung, Tuen Mun	Wastewater discharged to Tai Lam Chung Nullah, contravening s.8(1)(a) of the WPCO Cap. 358	Oct 1993	Jan 1999	Installed a package treatment plant. Eventually to connect to new public sewers in 2006.	Aug 2002	CSD/ArchSD	Interim: increased desludging frequency.
9	Tai Lam Correctional Institution at Tai Lam Chung, Tuen Mun	Wastewater discharged to Tai Lam Chung Nullah, contravening s.8(1)(a) of the WPCO Cap. 358	Oct 1993	Jan 1999	Installed a new STP	Aug 2001	CSD/ArchSD	Interim: increased desludging frequency.
10	Siu Lam Psychiatric Centre at 16.5 Milestone, Castle Peak Road, Tuen Mun	Wastewater discharged to stream, contravening s.8(1)(a) of the WPCO Cap. 358	July 1998	Jan 1999	Constructed a humus tank, upgraded filtration tank and installed an UV plant.	Mar 2001	CSD/ArchSD	Interim: installed 2 additional under-sink grease traps and increased desludging frequency.
11	Tai O Fire Station	Wastewater from septic tank discharged to sea, contravening s.8(1)(a) of the WPCO Cap. 358	June 1994	Jan 1999	Provided sewer connection to the new trunk sewer.	Jan 2000	FSD/ArchSD	
12	Tai O Post Office & Quarters	Wastewater discharged to sea, contravening s.8(1)(a) of the WPCO Cap. 358	June 1994	Jan 1999	Provided sewer connection to the new trunk sewer.	Jan 2000	Post Office/ ArchSD	
13	Tai O Police Station	Wastewater from septic tank discharged to sea, contravening s.8(1)(a) of the WPCO Cap. 358	June 1994	Jan 1999	Provided sewer connection to the new trunk sewer.	Jan 2000	HKPF/ArchSD	
14	Lau Fau Shan Police Station, Lau Fau Shan, Yuen Long	Wastewater discharged into the waters of Hong Kong, contravening s.8(1)(a) of the WPCO Cap. 358	Jan 1996	Jan 1999	Installed a new package treatment plant.	Jan 2000	HKPF/ArchSD	

**156 Contraventions in Government Facilities that were reported to the Chief Secretary's Committee / Policy Committee since 1999**

<b>Item</b>	<b>Location</b>	<b>Nature of contravention</b>	<b>Date discovered</b>	<b>Date reported</b>	<b>Long-term Improvement Measures</b>	<b>Date of completion</b>	<b>Responsible Department / Works Agent</b>	<b>Notes</b>
15	Tsim Bei Tsui Police Post, Shum Wan Road, Tsim Bei Tsui, Lau Fau Shan, Yuen Long.	Wastewater discharged into the waters of Hong Kong, contravening s.8(1)(a) of the WPCO Cap. 358	Jan 1996	Jan 1999	Installed a new package treatment plant.	Jan 2000	HKPF/ArchSD	
16	Sha Tau Kok Border Post, Sha Tau Kok Road	Wastewater discharged to waters of Hong Kong, contravening s.8(1)(a) of the WPCO Cap. 358	May 1993	Jan 1999	Connected the discharge from grease traps to public foul sewer.	Jan 2000	HKPF/ArchSD	
17	Queen's Hill Camp, Plant A, Fanling	Wastewater discharged to stream, contravening s.8(1)(a) of the WPCO Cap. 358	Sep 1992	Jan 1999	The camp was vacated in September 2001.	Feb 2000	HKPF/DSD	Interim: modified the existing drainage works
18	Queen's Hill Camp, Plant C, Fanling	Wastewater discharged to stream, contravening s.8(1)(a) of the WPCO Cap. 358	Sep 1992	Jan 1999	The camp was vacated in 2000.	Jan 2000	HKPF/DSD	
19	Man Kam To Terminal, Man Kam To Control Point	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap. 358	May 1993	Jan 1999	Constructed a new STP.	Dec 2001	Imm D/ArchSD	Interim: more cleansing of the septic tank, grease trap and filtration tank
20	Sha Tau Kok Control Point, Sha Tau Kok	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap. 358	May 1993	Jan 1999	Constructed sewer for connection to nearby sewer.	Aug 2001	Imm D/ArchSD	Interim: more cleansing of the septic tank, grease trap and filtration tank

**156 Contraventions in Government Facilities that were reported to the Chief Secretary's Committee / Policy Committee since 1999**

<b>Item</b>	<b>Location</b>	<b>Nature of contravention</b>	<b>Date discovered</b>	<b>Date reported</b>	<b>Long-term Improvement Measures</b>	<b>Date of completion</b>	<b>Responsible Department / Works Agent</b>	<b>Notes</b>
21	Lower Sham Tseng Resite Village (No. 46-63) communal septic tank, Tsuen Wan	Discharge of substandard effluent to nullah, contravening s.17(B) of the WPC(G)R	Oct 1993	Jan 1999	To construct sewer for connection to Sham Tseng Sewage Treatment System.	Dec 2001	LandsD/DSD	Interim: installed an additional treatment facility for enhancing the effluent quality, continued desludging operation. Treatment facility completed in Dec 2001 with effluent meeting EPD standard.
22	Upper Sham Tseng Resite Village (No. 1 – 45) communal septic tank, Tsuen Wan	Discharge of substandard effluent to nullah, contravening s.17(B) of the WPC(G)R	Oct 1993	Jan 1999	To construct sewer for connection to Sham Tseng Sewage Treatment System.	Dec 2001	LandsD/DSD	Interim: installed an additional treatment facility for enhancing the effluent quality, continued desludging operation. Treatment facility completed in Dec 2001 with effluent meeting EPD standard.
23	Yuen Tun Resite Village communal septic tank, Tsuen Wan	Discharge of substandard effluent to coastal water, contravening s.17(B) of the WPC(G)R	Jan 1996	Jan 1999	To construct sewer for connection to Sham Tseng Sewage Treatment System.	Dec 2001	LandsD/DSD	Interim: installed an additional treatment facility for enhancing the effluent quality, continued desludging operation. Treatment facility completed in Dec 2001 with effluent meeting EPD standard.
24	O Pui Shan Boy Home, Kwai Tsing	Wastewater discharge to inland water, contravening s.8(1)(b) of the WPCO Cap. 358	Mar 1998	Jan 1999	Constructed a new STP	Jan 2002	SWD/DSD	

**156 Contraventions in Government Facilities that were reported to the Chief Secretary's Committee / Policy Committee since 1999**

<b>Item</b>	<b>Location</b>	<b>Nature of contravention</b>	<b>Date discovered</b>	<b>Date reported</b>	<b>Long-term Improvement Measures</b>	<b>Date of completion</b>	<b>Responsible Department / Works Agent</b>	<b>Notes</b>
25	Shek Lei Pui Water Treatment Works	Untreated wastewater discharged to public sewer, storm drain or waters of Hong Kong, contravening s.9(1)(a), s.9(1)(b) and s.8(1)(a) of the WPCO Cap. 358 respectively.	1998	Jan 1999	Improvement works included thickening, dewatering and transfer sludge for landfill disposal.	Jan 2000	WSD/WSD	
26	Tai Po Road Water Treatment Works	Untreated wastewater discharged to public sewer, storm drain or waters of Hong Kong, contravening s.9(1)(a), s.9(1)(b) and s.8(1)(a) of the WPCO Cap. 358 respectively.	1998	Jan 1999	Improvement works included thickening, dewatering and transfer sludge for landfill disposal.	Jan 2000	WSD/WSD	
27	Tsuen Wan Water Treatment Works	Untreated wastewater discharged to public sewer, storm drain or waters of Hong Kong, contravening s.9(1)(a), s.9(1)(b) and s.8(1)(a) of the WPCO Cap. 358 respectively.	1998	Jan 1999	Improvement works included thickening, dewatering and transfer sludge for landfill disposal.	Mar 2000	WSD/WSD	
28	Silvermine Bay Water Treatment Works	Untreated wastewater discharged to public sewer, storm drain or waters of Hong Kong, contravening s.9(1)(a), s.9(1)(b) and s.8(1)(a) of the WPCO Cap. 358 respectively.	1998	Jan 1999	Improvement works included thickening, dewatering and transfer sludge for landfill disposal.	Jan 2000	WSD/WSD	

**156 Contraventions in Government Facilities that were reported to the Chief Secretary's Committee / Policy Committee since 1999**

<b>Item</b>	<b>Location</b>	<b>Nature of contravention</b>	<b>Date discovered</b>	<b>Date reported</b>	<b>Long-term Improvement Measures</b>	<b>Date of completion</b>	<b>Responsible Department / Works Agent</b>	<b>Notes</b>
29	Tuen Mun Water Treatment Works	Untreated wastewater discharged to public sewer, storm drain or waters of Hong Kong, contravening s.9(1)(a), s.9(1)(b) and s.8(1)(a) of the WPCO Cap. 358 respectively.	1998	Jan 1999	Improvement works included thickening, dewatering and transfer sludge for landfill disposal.	Jun 2000	WSD/WSD	
30	Tai O Water Treatment Works	Untreated wastewater discharged to public sewer, storm drain or waters of Hong Kong, contravening s.9(1)(a), s.9(1)(b) and s.8(1)(a) of the WPCO Cap. 358 respectively.	1998	Jan 1999	Improvement works included thickening, dewatering and transfer sludge for landfill disposal.	Feb 2000	WSD/WSD	Interim: installed a temporary treatment facility
31	Eastern Water Treatment Works, Wanchai	Untreated wastewater discharged to public sewer, storm drain or waters of Hong Kong, contravening s.9(1)(a), s.9(1)(b) and s.8(1)(a) of the WPCO Cap. 358 respectively.	1998	Jan 1999	Improvement works included thickening, dewatering and transfer sludge for landfill disposal.	Feb 1999	WSD/WSD	
32	Aberdeen Water Treatment Works	Untreated wastewater discharged to public sewer, storm drain or waters of Hong Kong, contravening s.9(1)(a), s.9(1)(b) and s.8(1)(a) of the WPCO Cap. 358 respectively.	1998	Jan 1999	Improvement works included thickening, dewatering and transfer sludge for landfill disposal.	Feb 1999	WSD/WSD	

**156 Contraventions in Government Facilities that were reported to the Chief Secretary's Committee / Policy Committee since 1999**

<b>Item</b>	<b>Location</b>	<b>Nature of contravention</b>	<b>Date discovered</b>	<b>Date reported</b>	<b>Long-term Improvement Measures</b>	<b>Date of completion</b>	<b>Responsible Department / Works Agent</b>	<b>Notes</b>
33	Red Hill Water Treatment Works	Untreated wastewater discharged to public sewer, storm drain or waters of Hong Kong, contravening s.9(1)(a), s.9(1)(b) and s.8(1)(a) of the WPCO Cap. 358 respectively.	1998	Jan 1999	Improvement works included thickening, dewatering and transfer sludge for landfill disposal.	Feb 1999	WSD/WSD	
34	Water Treatment Works at Kwun Hang Village, Sai Sha Road, Sai Kung	Noise from fan at pump room exceeding limit, contravening s13(1)(c ) of the NCO	Mar 1998	Jan 1999	Installed timber enclosure to reduce the noise level.	Feb 1999	WSD/WSD	
35	162 fresh water and 42 salt water service reservoirs together with header tanks in the territory	Wastewater discharged to stream and storm drain, contravening s.8(1)(b) & s.9(1)(b) of the WPCO Cap 358 respectively	1998	Jan 1999	Adopted alternative cleaning method.	Oct 1999	WSD/WSD	
36	Middle Road Multistorey Carpark Building, Middle Road, Tsim Sha Tsui	Noise from 2 new air-conditioning chiller plants exceeding noise limit stipulated in the relevant technical memorandum issued under the NCO	May 1999	Dec 1999	Installed noise abatement measures	Jan 2000	C&ED/ArchSD	
37	Kowloon City Divisional Police Station, Argyle St	Wastewater from laundry on roof floor discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap. 358	Jan 1996	Jan 1999	Improved sewerage works	Feb 1999	HKPF	

**156 Contraventions in Government Facilities that were reported to the Chief Secretary's Committee / Policy Committee since 1999**

<b>Item</b>	<b>Location</b>	<b>Nature of contravention</b>	<b>Date discovered</b>	<b>Date reported</b>	<b>Long-term Improvement Measures</b>	<b>Date of completion</b>	<b>Responsible Department / Works Agent</b>	<b>Notes</b>
38	Kowloon City District Police Station (Homantin Police Station), 99 Princess Margaret Road	Wastewater from refuse bay discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap. 358	Jan 1996	Jan 1999	Improved sewerage works	Feb 1999	HKPF	
39	Ma Tau Kok Quarantine Station at 63 Ma Tau Kok Road, Tokwawan	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap. 358	Sep 1997	Jan 1999	Closed after commissioning of Sheung Shui Abattoir.	Oct 1999	AFCD/ArchSD	Interim: connected to foul sewer in mid 1999
40	Cheung Sha Wan Temporary Wholesale Poultry Market at 1-4 Hing Wah Street, Cheung Sha Wan	Substandard wastewater discharged from the washing activities, contravening s.17B of the WPC(G)R.	June 1998	Jan 1999	AFCD decided not to re-open the slaughter unit.	Feb 1999	AFCD	
41	Yuen Tun Camp, Tsing Lung Tau, Tsuen Wan	Substandard effluent discharged to waters of Hong Kong, contravening s.17B of WPC(G)R.	Nov 1993	Jan 1999	Installed a package sewage treatment plant.	Dec 2000	CAS/ArchSD	Interim: increased desludging frequency
42	Ma Po Ping Prison, Lantau	Wastewater discharged to sea and to storm drain, contravening s.8(1)(a) & s.9(1)(a) of the WPCO Cap. 358 respectively.	Sep 1994	Jan 1999	Installed an equalization tank and repaired rotating biological contactor	Oct 1999	CSD/DSD	
43	Tai Tam Gap Correctional Center	Wastewater discharged to stream, contravening s.8(1)(a) of the WPCO Cap. 358	June 1994	Jan 1999	Provided sewer connection	Mar 1999	CSD/DSD	
44	Stanley Prison	Wastewater discharged to coastal water, contravening s.8(1)(a) of the WPCO Cap. 358	June 1991	Jan 1999	Improved sewerage works	July 1999	CSD/ArchSD	



**156 Contraventions in Government Facilities that were reported to the Chief Secretary's Committee / Policy Committee since 1999**

<b>Item</b>	<b>Location</b>	<b>Nature of contravention</b>	<b>Date discovered</b>	<b>Date reported</b>	<b>Long-term Improvement Measures</b>	<b>Date of completion</b>	<b>Responsible Department / Works Agent</b>	<b>Notes</b>
45	Tung Tau Correctional Institute	Wastewater discharged to coastal water, contravening s.8(1)(a) of the WPCO Cap. 358	July 1997	Jan 1999	Provided permanent sewer.	Feb 1999	CSD/DSD	
46	Consort Rise Septic Tank, Southern	Substandard effluent discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap. 358	Jan 1995	Jan 1999	Diverted sewage to Sandy Bay sewage screening plant.	Oct 1999	DSD/DSD	Interim: increased desludging frequency
47	Sewage Treatment Works at Stonecutters Island	Emission of objectionable odour, contravening s.10 of the APCO	May 1997	Jan 1999	Constructed enclosure and installed odour control system.	Oct 1999	DSD/DSD	Interim: minimized sludge retention time and covered sludge cake silos by plastic sheets.
48	To Kwa Wan Sewage Screening Plant, Bailey Street, To Kwa Wan	Effluent discharge in breach of licence condition, contravening s.17B of the WPC(G)R	Nov 1997	Jan 1999	Sewage discharged into Strategic Sewage Disposal Scheme Stage 1 system.	Oct 1999	DSD/DSD	
49	North Point Sewage Screening Plant	Substandard effluent discharge, contravening s.17(B) of the WPC(G)R	Aug 1998	Jan 1999	Repaired the leaking submarine outfalls.	Feb 1999	DSD/DSD	
50	Chai Wan Sewage Screening Plant	Substandard effluent discharge, contravening s.17(B) of the WPC(G)R	June 1994	Jan 1999	Repaired the leaking submarine outfalls.	Oct 1999	DSD/DSD	
51	Wan Chai East Sewage Screening Plant	Substandard effluent discharge, contravening s.17(B) of the WPC(G)R	Nov 1997	Jan 1999	Repaired the leaking submarine outfalls.	Feb 1999	DSD/DSD	

**156 Contraventions in Government Facilities that were reported to the Chief Secretary's Committee / Policy Committee since 1999**

<b>Item</b>	<b>Location</b>	<b>Nature of contravention</b>	<b>Date discovered</b>	<b>Date reported</b>	<b>Long-term Improvement Measures</b>	<b>Date of completion</b>	<b>Responsible Department / Works Agent</b>	<b>Notes</b>
52	Wan Chai West Sewage Screening Plant	Substandard effluent discharge, contravening s.17(B) of the WPC(G)R	Nov 1997	Jan 1999	Repaired the leaking submarine outfalls.	Feb 1999	DSD/DSD	
53	Kowloon South Sewage Screening Plant, Salisbury.	Effluent discharge in breach of licence condition, contravening s.17(B) of the WPC(G)R	Nov 1997	Jan 1999	Repaired the leaking submarine outfalls.	Feb 1999	DSD/DSD	
54	Tai Lam Fire Station, Tuen Mun	Noise from engines, cutters and pumps exceeding limit, contravening s13(1)(c) of the NCO	Aug 1997	Jan 1999	Built solid walls at the 3 sides of the fire station.	Feb 1999	FSD/ArchSD	
55	Pak Heung Fire Services Training School at Fan Kam Road, Pak Heung, Yuen Long	Wastewater discharged into waters of Hong Kong, contravening s.8(1)(a) of the WPCO Cap. 358	Sep 1997	Jan 1999	Upgraded the existing STP	Oct 1999	FSD/ArchSD	
56	Lok Ma Chau Border Control Point, Lok Ma Chau, Yuen Long	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap. 358	Nov 1994	Jan 1999	Installed a sewage treatment plant.	Feb 1999	ImmD/ArchSD	Interim: provided portable toilets.
57	Kwun Tong Swimming Pool at Tsui Ping Road	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Mar 1999	Dec 1999	Rectified the drainage works.	July 2000	LCSD/ArchSD	
58	Lei Cheng Uk Park Swimming Pool	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	May 1997	Dec 1999	Rectified the drainage works.	July 2000	LCSD/ArchSD	

**156 Contraventions in Government Facilities that were reported to the Chief Secretary's Committee / Policy Committee since 1999**

<b>Item</b>	<b>Location</b>	<b>Nature of contravention</b>	<b>Date discovered</b>	<b>Date reported</b>	<b>Long-term Improvement Measures</b>	<b>Date of completion</b>	<b>Responsible Department / Works Agent</b>	<b>Notes</b>
59	Lai Chi Kok Park Swimming Pool	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	May 1997	Dec 1999	Rectified the drainage works.	Aug 2000	LCSD/ArchSD	
60	Cha Kwo Ling Vehicle Depot	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	July 1996	Dec 1999	Rectified the drainage works.	April 2001	FEHD/ArchSD	
61	Beach facilities at Stanley Main Beach	Wastewater discharged to beach, contravening s.8(1)(a) of the WPCO Cap 358	Oct 1994	Dec 1999	Installed a septic tank.	Aug 2000	LCSD/ArchSD	
62	Beach facilities at Deep Water Bay	Wastewater discharged to beach, contravening s.8(1)(a) of the WPCO Cap 358	Oct 1994	Dec 1999	Provided improvement measures	Aug 2001	LCSD/ArchSD	
63	Public toilets at Tsim Sha Tsui Ferry Pier Concourse	Wastewater discharged to sea, contravening s.8(1)(a) of the WPCO Cap 358	Aug 1998	Dec 1999	Connected to existing sewer of HK Cultural Centre	April 2001	FEHD/ArchSD	
64	Luen Wo Hui Hawkers Bazaar, Luen Wo Hui, Fanling	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	June 1994	Dec 1999	Bazaar closed upon completion of a new market.	Nov 2001	FEHD/ArchSD	Interim: wastewater was diverted to the nearby foul sewer.
65	Lee Chung Street Cooked Food Stalls	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Nov 1994	Dec 1999	The market closed and the cooked food operators re-sited to the new Chai Wan UC Complex.	Mar 2000	FEHD/ArchSD	Interim: improved drainage works.

**156 Contraventions in Government Facilities that were reported to the Chief Secretary's Committee / Policy Committee since 1999**

<b>Item</b>	<b>Location</b>	<b>Nature of contravention</b>	<b>Date discovered</b>	<b>Date reported</b>	<b>Long-term Improvement Measures</b>	<b>Date of completion</b>	<b>Responsible Department / Works Agent</b>	<b>Notes</b>
66	Boundary Street Market	Substandard wastewater discharged to sewer, contravening s.17B of the WPC(G)R and wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	July 1996	Dec 1999	Rectified the drainage works.	Apr 2000	FEHD/ArchSD	Interim: installed additional grease traps and surface channel
67	Tai Kok Tsui Cooked Food Bazaar	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Oct 1996	Dec 1999	Rectified the drainage works	May 2001	FEHD/ArchSD	
68	Canton Road Cooked Food Bazaar	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Aug 1996	Dec 1999	Rectified the drainage works.	July 2000	FEHD/ArchSD	
69	Stanley Market	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Mar 1996	Dec 1999	Relocated to a temporary market.	Dec 1999	FEHD/ArchSD	
70	Cha Kwo Ling Market, Kwun Tong	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Mar 1996	Dec 1999	Rectified the drainage works.	Aug 2000	FEHD/ArchSD	
71	Cooked Food Bazaar at Lai Yip Street, Kwun Tong	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	May 1997	Dec 1999	Installed a grease trap and rectified the drainage works.	Mar 2001	FEHD/ArchSD	

**156 Contraventions in Government Facilities that were reported to the Chief Secretary's Committee / Policy Committee since 1999**

<b>Item</b>	<b>Location</b>	<b>Nature of contravention</b>	<b>Date discovered</b>	<b>Date reported</b>	<b>Long-term Improvement Measures</b>	<b>Date of completion</b>	<b>Responsible Department / Works Agent</b>	<b>Notes</b>
72	Sai Wan Ho Market and Cooked Food Stall	Substandard wastewater discharged to sewer, contravening s.17B of the WPC(G)R	Nov 1994	Dec 1999	Improved house keeping such as stepping up grease trap clearing and desludging	Dec 1999	FEHD/ArchSD	
73	Shau Kei Wan Market	Substandard wastewater discharged to sewer, contravening s.17B of the WPC(G)R	Nov 1994	Dec 1999	Improved the drainage works	Mar 2001	FEHD/ArchSD	Interim: more clean up of individual grease traps.
74	North Point Market	Substandard wastewater discharged to sewer, contravening s.17B of the WPC(G)R	Nov 1996	Dec 1999	Installed a grease trap	Aug 2000	FEHD/ArchSD	
75	Causeway Bay Market	Substandard wastewater discharged to sewer, contravening s.17B of the WPC(G)R	Nov 1996	Dec 1999	Installed a grease trap	May 2000	FEHD/ArchSD	
76	Electric Road Market	Substandard wastewater discharged to sewer, contravening s.17B of the WPC(G)R	Nov 1996	Dec 1999	Installed a grease trap	May 2000	FEHD/ArchSD	
77	Yue Wan Market	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Nov 1994	Dec 1999	Upgraded the existing grease trap and rectified the drainage works.	May 2000	FEHD/ArchSD	
78	Tai Po Temporary Market and Cooked Food Stall, Po Heung Street, Tai Po.	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	May 1998	Dec 1999	Temporary market reprovisioned in a new market complex.	Nov 2001	FEHD/ArchSD	Interim: provided drainage improvement works.
79	Sham Tseng Temporary Market, Tsuen Wan	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Dec 1993	Dec 1999	Wastewater discharged into Sham Tseng Sewage Treatment Works.	Aug 2000	FEHD/ArchSD	Interim: installed a cesspool for tankering away effluent.

**156 Contraventions in Government Facilities that were reported to the Chief Secretary's Committee / Policy Committee since 1999**

<b>Item</b>	<b>Location</b>	<b>Nature of contravention</b>	<b>Date discovered</b>	<b>Date reported</b>	<b>Long-term Improvement Measures</b>	<b>Date of completion</b>	<b>Responsible Department / Works Agent</b>	<b>Notes</b>
80	Heung Che Street Market and Cooked Food Market, Tsuen Wan	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Sep 1995	Dec 1999	Provided sewer connection and constructed grease traps and sump pits.	Aug 2000	FEHD/ArchSD	
81	Luen Yan Street Cooked Food Bazaar, Tsuen Wan	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	May 1996	Dec 1999	Most licensees surrendered their licences for ex-gratia allowance.	Sep 2000	FEHD/ArchSD	Interim: constructed a dry weather flow interceptor
82	Kam Tin Market, Kam Tin Road, Kam Tin, Yuen Long	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Mar 1997	Dec 1999	Installed a package wastewater treatment plant.	Nov 2002	FEHD/ArchSD	Interim: installed under-sink grease traps
83	Chai Wan Temporary Market & its refuse collection point (RCP)	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Nov 1994	Dec 1999	The market and its RCP closed down upon the commissioning of the new Chai Wan UC Complex.	Dec 1999	FEHD/ArchSD	Interim: stepped up clearing frequency of the grease traps.
84	RCP at Lai Yip Street Kwun Tong	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	April 1999	Dec 1999	Rectified the drainage works.	Mar 2001	FEHD/ArchSD	
85	RCP at Island Road	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	April 1997	Dec 1999	Connected to a new sewer in Deep Water Bay.	July 2003	FEHD/ArchSD	Interim: improved house keeping to reduce pollution
86	RCP at Stanley Village Road	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	April 1998	Dec 1999	RCP closed down after the opening of the new RCP at new Stanley market.	Feb 2000	FEHD/ArchSD	

**156 Contraventions in Government Facilities that were reported to the Chief Secretary's Committee / Policy Committee since 1999**

<b>Item</b>	<b>Location</b>	<b>Nature of contravention</b>	<b>Date discovered</b>	<b>Date reported</b>	<b>Long-term Improvement Measures</b>	<b>Date of completion</b>	<b>Responsible Department / Works Agent</b>	<b>Notes</b>
87	RCP at Muk Min Ha Resite Village, Tsuen Wan	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Feb 1999	Dec 1999	Improved drainage inside RCP and connected to nearby sewer.	Oct 2000	FEHD/HAD	Interim: cleaned by mopping instead of flushing
88	RCP at Hilltop Road, Tsuen Wan	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Feb 1999	Dec 1999	Improved drainage inside RCP and connected to nearby sewer.	Oct 2000	FEHD/HAD	Interim: cleaned by mopping instead of flushing
89	RCP at Lo Wai Village (Tung Po Tor), Tsuen Wan	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Feb 1999	Dec 1999	Installed a cesspool.	Oct 2000	FEHD/HAD	Interim: cleaned by mopping instead of flushing
90	RCP at Sai Lau Kok Tsuen, Tsuen Wan	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Feb 1999	Dec 1999	Improved drainage inside RCP and connected to nearby sewer.	Oct 2000	FEHD/HAD	Interim: cleaned by mopping instead of flushing
91	RCP at Ting Kwok Street, Tsuen Wan	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Feb 1999	Dec 1999	Improved drainage inside RCP and connected to nearby sewer.	Oct 2000	FEHD/HAD	Interim: cleaned by mopping instead of flushing
92	RCP at Ting Fung Street, Tsuen Wan	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Feb 1999	Dec 1999	Improved drainage inside RCP and connected to nearby sewer.	Oct 2000	FEHD/HAD	Interim: cleaned by mopping instead of flushing
93	RCP at Lei Shu Road, Tsuen Wan	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Feb 1999	Dec 1999	Improved drainage inside RCP and connected to nearby sewer.	Oct 2000	FEHD/HAD	Interim: cleaned by mopping instead of flushing
94	RCP at Hoi Pa Resite Village, Tsuen Wan	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Feb 1999	Dec 1999	Installed a cesspool.	Oct 2000	FEHD/HAD	Interim: cleaned by mopping instead of flushing

**156 Contraventions in Government Facilities that were reported to the Chief Secretary's Committee / Policy Committee since 1999**

<b>Item</b>	<b>Location</b>	<b>Nature of contravention</b>	<b>Date discovered</b>	<b>Date reported</b>	<b>Long-term Improvement Measures</b>	<b>Date of completion</b>	<b>Responsible Department / Works Agent</b>	<b>Notes</b>
95	RCP at Sheung Kwai Chung Village, Tsuen Wan	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Feb 1999	Dec 1999	Installed a cesspool.	Oct 2000	FEHD/HAD	Interim: cleaned by mopping instead of flushing
96	RCP at Yau Ma Hom Road, Tsuen Wan	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Feb 1999	Dec 1999	Improved drainage inside RCP and connected to nearby sewer.	Oct 2000	FEHD/HAD	Interim: cleaned by mopping instead of flushing
97	RCP at Tai Lin Pai Road, Kwai Chung	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	July 1999	Dec 1999	Improved drainage works.	Jan 2000	FEHD/ArchSD	Interim: cleaned by mopping instead of flushing
98	RCP at Kau Wah Keng Old Village, Kwai Chung	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Sep 1999	Dec 1999	Improved drainage works	Oct 2000	FEHD/HAD	Interim: cleaned by mopping instead of flushing
99	RCP at Ta Chuen Ping Street, Kwai Chung	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	June 1998	Dec 1999	Improved drainage works.	Jan 2000	FEHD/ArchSD	Interim: cleaned by mopping instead of flushing
100	RCP at Tai Yuen Street, Kwai Chung	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Aug 1999	Dec 1999	Improved drainage works	Sep 2000	FEHD/ArchSD	Interim: cleaned by mopping instead of flushing
101	RCP at Shan Ha Tsuen, Yuen Long	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Oct 1994	Dec 1999	Installed a cesspool	Oct 2000	FEHD/HAD	Interim: used less water for cleansing to minimize pollution
102	RCP at Shui Tsiu San Tsuen, Tai Tong Road, Yuen Long	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Oct 1994	Dec 1999	Installed a cesspool	Oct 2000	FEHD/HAD	Interim: used less water for cleansing to minimize pollution



**156 Contraventions in Government Facilities that were reported to the Chief Secretary's Committee / Policy Committee since 1999**

<b>Item</b>	<b>Location</b>	<b>Nature of contravention</b>	<b>Date discovered</b>	<b>Date reported</b>	<b>Long-term Improvement Measures</b>	<b>Date of completion</b>	<b>Responsible Department / Works Agent</b>	<b>Notes</b>
103	RCP at Ngan Yuen, Hung Shui Kiu, Yuen Long	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Oct 1994	Dec 1999	Connected to nearby sewer.	Aug 2001	FEHD/HAD	Interim: used less water for cleansing to minimize pollution
104	RCP at Shek Po Road, Hung Shui Kiu, Yuen Long	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Oct 1994	Dec 1999	Improved drainage works inside the RCP and connected to nearby sewer.	Oct 2000	FEHD/HAD	Interim: used less water for cleansing to minimize pollution
105	RCP at Lok Kui Lau, Ping Shan, Yuen Long	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Oct 1994	Dec 1999	Installed a cesspool	Oct 2000	FEHD/HAD	Interim: used less water for cleansing to minimize pollution
106	RCP at Ping Shan, Yuen Long	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Oct 1994	Dec 1999	Installed a cesspool	Oct 2000	FEHD/HAD	Interim: used less water for cleansing to minimize pollution
107	RCP at Shek Po Road Car Park, Hung Shui Kiu, Yuen Long	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Oct 1994	Dec 1999	Installed a cesspool	Oct 2000	FEHD/HAD	Interim: used less water for cleansing to minimize pollution
108	RCP at Sha Chau Lei, Hung Shui Kiu, Yuen Long	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Oct 1994	Dec 1999	Installed a cesspool	Oct 2000	FEHD/HAD	Interim: used less water for cleansing to minimize pollution
109	RCP at Po Yuen, Castle Peak Road, Tuen Mun	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	1999	Dec 1999	Installed a cesspool and improved drainage works	Sep 2000	FEHD/HAD	Interim: used less water for cleansing to minimize pollution
110	RCP at Kei Lun Wai, Tuen Mun	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	1999	Dec 1999	Improved drainage works inside the RCP and connected to nearby sewer	Sep 2000	FEHD/HAD	Interim: cleaned by mopping instead of flushing

**156 Contraventions in Government Facilities that were reported to the Chief Secretary's Committee / Policy Committee since 1999**

<b>Item</b>	<b>Location</b>	<b>Nature of contravention</b>	<b>Date discovered</b>	<b>Date reported</b>	<b>Long-term Improvement Measures</b>	<b>Date of completion</b>	<b>Responsible Department / Works Agent</b>	<b>Notes</b>
111	RCP at Wong Yin Street, Tuen Mun	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	1999	Dec 1999	Installed a cesspool and improved drainage works	Sep 2000	FEHD/HAD	Interim: cleaned by mopping instead of flushing
112	RCP at Tsing Chuen Road, Tuen Mun	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	1999	Dec 1999	Installed a cesspool and improved drainage works	Sep 2000	FEHD/HAD	Interim: used less water for cleansing to minimize pollution
113	RCP at Hung Cheung Road, Area 12, Tuen Mun	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	1999	Dec 1999	Repaired the defective pump	May 2000	FEHD/HAD	Interim: cleaned by mopping instead of flushing
114	RCP at Fuk Hang Tsuen, near Lam Tei Gospel School, Tuen Mun	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	1999	Dec 1999	Installed a cesspool and improved drainage works	Sep 2000	FEHD/HAD	Interim: used less water for cleansing to minimize pollution
115	RCP at Fuk Hang Tsuen Road, Tuen Mun	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	1999	Dec 1999	Installed a cesspool and improved drainage works	Sep 2000	FEHD/HAD	Interim: used less water for cleansing to minimize pollution
116	RCP at Fu Tei Chung Tsuen, Tuen Mun	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	1999	Dec 1999	Installed a cesspool and improved drainage works	Sep 2000	FEHD/HAD	Interim: used less water for cleansing to minimize pollution
117	RCP at Wong Ka Wai, Area 36B, Tuen Mun	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	1999	Dec 1999	Installed a cesspool and improved drainage works	Sep 2000	FEHD/HAD	Interim: used less water for cleansing to minimize pollution
118	RCP at Tseng Tau Chung Tsuen, Tuen Mun	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	1999	Dec 1999	Installed a cesspool and improved drainage works	Sep 2000	FEHD/HAD	Interim: used less water for cleansing to minimize pollution

**156 Contraventions in Government Facilities that were reported to the Chief Secretary's Committee / Policy Committee since 1999**

<b>Item</b>	<b>Location</b>	<b>Nature of contravention</b>	<b>Date discovered</b>	<b>Date reported</b>	<b>Long-term Improvement Measures</b>	<b>Date of completion</b>	<b>Responsible Department / Works Agent</b>	<b>Notes</b>
119	RCP at Tai Sang Wai, San Tin, Yuen Long	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Oct 1994	Dec 1999	Installed a cesspool	Oct 2000	FEHD/HAD	Interim: cleaned by mopping instead of flushing
120	RCP at Long Hai, San Wai, San Tin, Yuen Long	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Oct 1994	Dec 1999	Installed a cesspool	Oct 2000	FEHD/HAD	Interim: cleaned by mopping instead of flushing
121	RCP at Fuk Hing Lane, San Tin, Yuen Long	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Oct 1994	Dec 1999	Installed a cesspool	Oct 2000	FEHD/HAD	Interim: cleaned by mopping instead of flushing
122	RCP at Pok Wai, San Tin, Yuen Long	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Oct 1994	Dec 1999	Installed a cesspool	Oct 2000	FEHD/HAD	Interim: cleaned by mopping instead of flushing
123	RCP at San Wai, San Tin, Yuen Long	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Oct 1994	Dec 1999	Installed a cesspool	Oct 2000	FEHD/HAD	Interim: cleaned by mopping instead of flushing
124	RCP at Wing Ning Lei, Wang Toi Shan, Kam Tin, Yuen Long	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Oct 1994	Dec 1999	Installed a cesspool	Oct 2000	FEHD/HAD	Interim: cleaned by mopping instead of flushing
125	RCP at Ngau Tam Mei Entrance, San Tin, Yuen Long	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Oct 1994	Dec 1999	Installed a cesspool	Oct 2000	FEHD/HAD	Interim: cleaned by mopping instead of flushing
126	RCP at Wai Chai Tsuen, Ngau Tam Mei, San Tin, Yuen Long	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Oct 1994	Dec 1999	Installed a cesspool	Oct 2000	FEHD/HAD	Interim: cleaned by mopping instead of flushing

**156 Contraventions in Government Facilities that were reported to the Chief Secretary's Committee / Policy Committee since 1999**

<b>Item</b>	<b>Location</b>	<b>Nature of contravention</b>	<b>Date discovered</b>	<b>Date reported</b>	<b>Long-term Improvement Measures</b>	<b>Date of completion</b>	<b>Responsible Department / Works Agent</b>	<b>Notes</b>
127	RCP at Kam Sheung Road, Kam Tin, Yuen Long	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Oct 1994	Dec 1999	Installed a cesspool	Oct 2000	FEHD/HAD	Interim: cleaned by mopping instead of flushing
128	RCP at side of Shek Wu Tong, Yuen Long	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Oct 1994	Dec 1999	Installed a cesspool	Oct 2000	FEHD/HAD	Interim: cleaned by mopping instead of flushing
129	RCP at Mo Fan Heung, Yuen Long	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Oct 1994	Dec 1999	Installed a cesspool	Nov 2000	FEHD/HAD	Interim: cleaned by mopping instead of flushing
130	RCP opposite to Fung Kut Heung, Yuen Long	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Oct 1994	Dec 1999	Installed a cesspool	Oct 2000	FEHD/HAD	Interim: cleaned by mopping instead of flushing
131	RCP at Hung Mo Kiu, Au Tau, Yuen Long	Wastewater discharged to storm drain, contravening s.9(1)(b) of the WPCO Cap 358	Oct 1994	Dec 1999	Installed a cesspool	Oct 2000	FEHD/HAD	Interim: cleaned by mopping instead of flushing
132	Tin Shui Wai Swimming Pool, 1 Tin Pak Road, Tin Sui Wai, Yuen Long	Wastewater arose from backwash of filtration system being discharged directly into storm drain without treatment, contravening s.9(1)(b) of the WPCO Cap 358	Feb 1999	Dec 1999	Connected to public foul sewer.	Aug 2000	LCSD/ArchSD	

**156 Contraventions in Government Facilities that were reported to the Chief Secretary's Committee / Policy Committee since 1999**

<b>Item</b>	<b>Location</b>	<b>Nature of contravention</b>	<b>Date discovered</b>	<b>Date reported</b>	<b>Long-term Improvement Measures</b>	<b>Date of Completion</b>	<b>Responsible Department / Works Agent</b>	<b>Notes</b>
133	Cape Collinson Correctional Centre	Wastewater discharged to sea, contravening s.8(1)(a) of the WPCO Cap. 358	May 1994	Jan 1999	To install a new Sewage Treatment Plant (STP)	March 2004	CSD/DSD	Interim: frequent desludging service to septic tanks. Civil works of the STP completed in Aug 2002. The E&M contractor experienced financial difficulty at end 2002. In May 2003, DSD hired a new E&M contractor and the E&M work re-commenced in May 2003. <b>All the required rectification works were completed by March 2004.</b>
134	Sha Tin Sewage Treatment Works (STSTW), Shui Chong Street, Shatin	Substandard effluent discharge, contravening s.17(B)(1) of the WPC(G)R	1999	Dec 1999	To upgrade the plant in 2 phases.	October 2004	DSD/DSD	Interim: reduced foaming and adjusted flow balancing during peak flow.  The Works of phase 1 started in February 2001. About 95% of civil works contract and 78% of E&M contract have been completed by September 2004. The commissioning of the liquid phase commenced on 23 <sup>rd</sup> June 2004 and the effluent quality has been satisfactory so far. <b>All the required rectification works were completed by October 2004.</b>

**156 Contraventions in Government Facilities that were reported to the Chief Secretary's Committee / Policy Committee since 1999**

Item	Location	Nature of contravention	Date discovered	Date reported	Long-term Improvement Measures	Date of Completion	Responsible Department / Works Agent	Notes
135	Fu Shan Crematorium, Tai Wai, Sha Tin	Dark smoke emission, contravening s.3 of the APC(S)R.	May 1996	Dec 1999	To replace the existing cremators.	September 2004	FEHD/ArchSD	Interim: EMSD increased maintenance frequency.  The Project was being implemented in two phases. The first phase was for the construction of new cremators for which the target completion date was at December 2003. The second phase was for demolition of old cremators and the associated refurbishment works which were to be commenced in April 2004 allowing three months for Testing & Commissioning and staff training for the new cremators. The original project completion date as stipulated in PWSC paper was June 2004. Phase I was completed on 7 March 2004. <b>Overall project was completed in September 2004.</b>
136	RCP at Ping Che Vegetable Market, Ta Kwu Ling (N57)	Wastewater discharged to storm drain contravening s.9(1)(b) of the WPCO, Cap. 358.	Apr 1994	March 2003	To reconstruct the RCP with cesspool.	December 2003	FEHD/ArchSD	Short term measures included cleaning the RCP by mopping instead of flushing. All site works were completed in December 2003.
137	RCP at Ha Shan Kai Wat, Ta Kwu Ling (N54)	Wastewater discharged to storm drain contravening s.9(1)(b) of the WPCO, Cap. 358.	Apr 1994	March 2003	To reconstruct the RCP with cesspool.	April 2004	FEHD/ArchSD	Short term measures included cleaning the RCP by mopping instead of flushing. All site works were completed in April 2004.

**156 Contraventions in Government Facilities that were reported to the Chief Secretary's Committee / Policy Committee since 1999**

<b>Item</b>	<b>Location</b>	<b>Nature of contravention</b>	<b>Date discovered</b>	<b>Date reported</b>	<b>Long-term Improvement Measures</b>	<b>Date of Completion</b>	<b>Responsible Department / Works Agent</b>	<b>Notes</b>
138	RCP at San Uk Ling, Man Kam To (N14)	Wastewater discharged to storm drain contravening s.9(1)(b) of the WPCO, Cap. 358.	Apr 1994	March 2003	To reconstruct the RCP with cesspool.	April 2004	FEHD/ArchSD	Short term measures included cleaning the RCP by mopping instead of flushing. All site works were completed in April 2004.
139	RCP at Cheung Po Tsuen, Man Kam To (N67)	Wastewater discharged to storm drain contravening s.9(1)(b) of the WPCO, Cap. 358.	Apr 1994	March 2003	To reconstruct the RCP with cesspool.	April 2004	FEHD/ArchSD	Short term measures included cleaning the RCP by mopping instead of flushing. All site works were completed in April 2004.
140	RCP at Wing Ling Wai, Fanling (N50)	Wastewater discharged to storm drain contravening s.9(1)(b) of the WPCO, Cap. 358.	Apr 1994	March 2003	To reconstruct the RCP with cesspool.	September 2004	FEHD/ArchSD	Short term measures included cleaning the RCP by mopping instead of flushing. All site works were completed in September 2004.
141	RCP at Kwan Tei Pak Tsuen, Fanling (N36)	Wastewater discharged to storm drain contravening s.9(1)(b) of the WPCO, Cap. 358.	Apr 1994	March 2003	To reconstruct the RCP with cesspool.	November 2003	FEHD/ArchSD	Short term measures included cleaning the RCP by mopping instead of flushing. All site works were completed in November 2003.
142	RCP at Man Kam To Road (N70)	Wastewater discharged to storm drain contravening s.9(1)(b) of the WPCO, Cap. 358.	Apr 1994	March 2003	To reconstruct the RCP with cesspool.	April 2004	FEHD/ArchSD	Short term measures included cleaning the RCP by mopping instead of flushing. All site works were completed in April 2004.
143	RCP at Wai Loi Tsuen, Sheung Shui (N19)	Wastewater discharged to storm drain contravening s.9(1)(b) of the WPCO, Cap. 358.	Apr 1998	March 2003	To reconstruct the RCP with cesspool.	November 2003	FEHD/ArchSD	Short term measures included cleaning the RCP by mopping instead of flushing. All site works were completed in November 2003.

**156 Contraventions in Government Facilities that were reported to the Chief Secretary's Committee / Policy Committee since 1999**

<b>Item</b>	<b>Location</b>	<b>Nature of contravention</b>	<b>Date discovered</b>	<b>Date reported</b>	<b>Long-term Improvement Measures</b>	<b>Date of Completion</b>	<b>Responsible Department / Works Agent</b>	<b>Notes</b>
144	RCP at Tai Yuen Tsuen, Sheung Shui (N11)	Wastewater discharged to storm drain contravening s.9(1)(b) of the WPCO, Cap. 358.	Apr 1998	March 2003	To reconstruct the RCP with cesspool.	December 2003	FEHD/ArchSD	Short term measures included cleaning the RCP by mopping instead of flushing. All site works were completed in December 2003.
145	RCP at Ping Kong San Tsuen, Fan Kam Road (N13)	Wastewater discharged to storm drain contravening s.9(1)(b) of the WPCO, Cap. 358.	Apr 1994	March 2003	To construct a cesspool at side of the RCP.	November 2003	FEHD/ArchSD	Short term measures included cleaning the RCP by mopping instead of flushing. All site works were completed in November 2003.
146	RCP at Yin Kwong Tsuen, Kwu Tung (N25)	Wastewater discharged to storm drain contravening s.9(1)(b) of the WPCO, Cap. 358.	Apr 1994	March 2003	To construct a cesspool at side of the RCP.	November 2003	FEHD/ArchSD	Short term measures included cleaning the RCP by mopping instead of flushing. All works were completed in November 2003.
147	RCP at Hung Kiu San Tsuen, Man Kam To Road (N6)	Wastewater discharged to storm drain contravening s.9(1)(b) of the WPCO, Cap. 358.	Apr 1994	March 2003	To reconstruct the RCP with cesspool.	September 2004	FEHD/ArchSD	Short term measures included cleaning the RCP by mopping instead of flushing. The drainage improvement works were completed in September 2004.
148	RCP at Shek Tsai Leng, Kwu Tung (N93)	Wastewater discharged to storm drain contravening s.9(1)(b) of the WPCO, Cap. 358.	Apr 1994	March 2003	To construct a cesspool at side of the RCP.	November 2003	FEHD/ArchSD	Short term measures included cleaning the RCP by mopping instead of flushing. All works were completed in November 2003.
149	RCP at Sam Mun Tsai Bus Terminus, Tai Po (TP-31)	Wastewater discharged to storm drain contravening s.9(1)(b) of the WPCO, Cap. 358.	Mar 2000	March 2003	To connect the drainage outlet to public sewer.	April 2004	FEHD/ArchSD	Short term measures included cleaning the RCP by mopping instead of flushing. All works completed by ArchSD in November 2003. Connection to public sewer was completed in April 2004.



**156 Contraventions in Government Facilities that were reported to the Chief Secretary's Committee / Policy Committee since 1999**

<b>Item</b>	<b>Location</b>	<b>Nature of contravention</b>	<b>Date discovered</b>	<b>Date reported</b>	<b>Long-term Improvement Measures</b>	<b>Date of Completion</b>	<b>Responsible Department / Works Agent</b>	<b>Notes</b>
150	RCP at Lo Tsz Tin Village, Tai Po (TP-87)	Wastewater discharged to storm drain contravening s.9(1)(b) of the WPCO, Cap. 358.	Mar 2000	March 2003	To construct a cesspool and connect the drainage outlet to public sewer.	November 2003	FEHD/ArchSD	Short term measures included cleaning the RCP by mopping instead of flushing. All works were completed in November 2003.
151	RCP at Tai Po Tau Village, Tai Po (TP-49)	Wastewater discharged to storm drain contravening s.9(1)(b) of the WPCO, Cap. 358.	Mar 2000	March 2003	To construct a cesspool.	December 2003	FEHD/ArchSD	Short term measures included cleaning the RCP by mopping instead of flushing. All works were completed in December 2003.
152	RCP at Tong Min Tsuen, Site 1, Tai Po (TP-66)	Wastewater discharged to storm drain contravening s.9(1)(b) of the WPCO, Cap. 358.	Mar 2000	March 2003	To construct a cesspool.	December 2003	FEHD/ArchSD	Short term measures included cleaning the RCP by mopping instead of flushing. All works were completed in December 2003.
153	RCP at Wai Tau, Site II, Tai Po (TP-52)	Wastewater discharged to storm drain contravening s.9(1)(b) of the WPCO, Cap. 358.	Mar 2000	March 2003	To construct a cesspool.	December 2003	FEHD/ArchSD	Short term measures included cleaning the RCP by mopping instead of flushing. All works were completed in December 2003.
154	RCP at San Tong Village, lam Tsuen, Tai Po (TP-68)	Wastewater discharged to storm drain contravening s.9(1)(b) of the WPCO, Cap. 358.	Mar 2000	March 2003	To construct a cesspool.	December 2003	FEHD/ArchSD	Short term measures included cleaning the RCP by mopping instead of flushing. All works were completed in December 2003.
155	RCP at Cheung Shue Tan, Tai Po Kau (TP-88)	Wastewater discharged to storm drain contravening s.9(1)(b) of the WPCO, Cap. 358.	Mar 2000	March 2003	To reconstruct the RCP with cesspool.	November 2003	FEHD/ArchSD	Short term measures included cleaning the RCP by mopping instead of flushing. All works were completed in November 2003.
156	RCP at Chek Nai Ping Village, Sha Tin (ST-17)	Wastewater discharged to storm drain contravening s.9(1)(b)	Mar 2000	March 2003	To construct a cesspool outside the RCP.	November 2003	FEHD/ArchSD	Short term measures included cleaning the RCP by mopping instead of flushing.

**156 Contraventions in Government Facilities that were reported to the Chief Secretary's Committee / Policy Committee since 1999**

		of the WPCO, Cap. 358.							All works were completed in November 2003.
--	--	------------------------	--	--	--	--	--	--	--

**Note:**

1. Abbreviations for ordinances  
 NCO : Noise Control Ordinance (Cap. 400)  
 WPCO : Water Pollution Control Ordinance (Cap. 358)  
 WPC(G)R: Water Pollution Control (General) Regulations (Cap. 358D)  
 APCO : Air Pollution Control Ordinance (Cap. 311)  
 APC(S)R : Air Pollution Control (Smoke) Regulations (Cap. 311C)
  
2. Abbreviations for Government departments:  
 AFCD : Agriculture, Fisheries and Conservation Department  
 Arch SD : Architectural Services Department  
 CAS : The Civil Aid Service  
 CSD : Correctional Services Department  
 C&ED : Customs and Excise Department  
 DSD : Drainage Services Department  
 FSD : Fire Services Department  
 FEHD : Food and Environmental Hygiene Department  
 HAD : Home Affairs Department  
 HKPF : Hong Kong Police Force  
 Imm D : Immigration Department  
 Lands D : Lands Department  
 LCSD : Leisure and Cultural Services Department  
 SWD : Social Welfare Department  
 WSD : Water Supplies Department

Environmental Protection Department  
 May 2006