

(Translation)

**LEGISLATIVE COUNCIL  
PUBLIC WORKS SUBCOMMITTEE**

PWP Item No. 440RO — District open space adjoining  
public housing development at Anderson Road

Enquiry letter of Hon Jeremy TAM to the Chairman of  
Public Works Subcommittee on 6 June 2017 on the above item

The information requested by Hon Jeremy TAM is set out as follows -

1. In the district open space adjoining public housing development at Anderson Road, we will adopt precast concrete and clay pavers instead of floor tiles as the paving materials.
2. The skid resistance of precast concrete and clay pavers of this project will be tested in accordance with European Standard BS EN 1344:2013, which includes testing the skid resistance under different degrees of slippery conditions. In the tender documents, we will specify the minimum skid resistance value for pavers to be 45 of which the skid risk potential is low. We will also request the contractor to submit relevant test reports to demonstrate the compliance of the specified skid resistance value. Pavers of similar skid resistance value are commonly used in the Housing Authority's projects including outdoor footpaths, and the anti-skid performance of these pavers is good.