



香港水喉潔具業商會有限公司
HONG KONG PLUMBING AND
SANITARY WARE TRADE ASSOCIATION LTD.

第二十三屆

Our Ref. : hkpswta 23/102

(2015-2017)

Date : 12 June 2017

理事會

Hon Leung Che-Cheung, BBS, MH, JP

理事長

Chairman

陳尚仁

Subcommittee on Waterworks (Amendment) Regulation 2017

副理事長

Dear Hon Leung,

劉利年

麥前耀

秘書

Re : Waterworks (Amendment) Regulation 2017
Invitation for Submission

熊志光

We refer to invitation for submissions from the subcommittee and to the best of understanding of the Waterworks (Amendment) Regulation 2017, we would like to furnish our comment as follows:

司庫

劉乙凡

會務主任

1) Section 10, Part 2, item 1

梁偉倫

Static pressure of Draw-off Taps and Stop Valve to with Stand 1,600 kpa

技術主任

We agree the working pressure for stop valve shall be 1,600 kpa, but we consider that 1,600 kpa is too much for draw-off taps.

陳永光

文教主任

Item 16 of Part 2, Section 10 mentioned that mixing valves shall comply with BS EN200:2008. The title of the BS EN200:2008 is "Sanitary wares-single taps and combination taps for water supply system". Table 1 of BS EN200:2008 state that Dynamic Pressure (static pressure) shall be of 10 bar (1,000 kpa).

黃松禧

編輯主任

林劍航

拓展主任

Thus, we believe that static pressure for Draw-off Tap shall be of 1,000 kpa and for stop valve shall be 1,600 kpa.

楊鎮文

福利主任

Thank you for your invitation for submissions, allowing us to express our views, and your Committee's due consideration to our comments and concerns will be highly appreciated.

何達祺

監事會

監事長

Yours Sincerely,

周雀圖

For and on behalf of


副監事長

Hong Kong Plumbing and Sanitary Ware Trade Association

古俊明

審核主任

曾寰宇


Ir Kenneth SY Chan
Chairman

監事

梁景恒

賴家賢

香港灣仔譚臣道七十六至七十八號七字樓

7/F., Thomson Centre, 76-78, Thomson Road, Hong Kong. Tel.: 2893 7628 Fax: (852) 2891 0040