

Hon. Life President
Mr Michael J. Green
Mr Peter O.K. Lam 林熙基

Our Ref: FSICA/17/Leg-EY/025
5 June 2017

The 17th Council (2016-2018)
Chairman
Mr Eric C.T. Yung 翁振騰

Mr Fred PANG
for Clerk to Subcommittee

Vice Chairman
Mr P.S. Ho 何沛森

Dear sir,

Hon. Treasurer
Mr K.V. Vong 王啟華

Subcommittee on Waterworks (Amendment) Regulation 2017

Thank you for your email dated 6th June 2017.

Hon. Secretary
Mr Simon H.T. Tsang 曾向東

With reference to the Waterworks (Amendment) Regulation 2017, FSICA agrees in principle the amendment of the Waterworks Regulation (Cap. 201A) to revise the requirements in relation to pipe or fittings installed in plumbing systems, we would like to have our views as below:

Council Member
Mr C.K. Chan 陳志堅
Mr Chan Cheong Ming 陳昌銘
Mr Eric K.Y. Lai 賴家賢
Mr Michael M.K. Lam 林文光
Mr W.S. Lee 李永成
Mr Ron C.H. Lung 龍智恆
Mr Ken C.K. Poon 潘正強
Mr Ben Wong 王家豪
Mr Rudolf K.C. Tam 譚啟聰
Mr H.W. Yu 余慶為

It is noted that the Fire Services System Installation is a non-portable water system and serves for firefighting purpose. In this connection, we would suggest to add a section name "Part 7 – Fire Services System Installation Immediate after Break Tank" under Schedule 2 of Cap 102A to facilitate a more effective rules and regulation in government water supply to Fire Services System Installation.

Hon. Legal Adviser
Ms Rebecca Ho 何穎恩律師

The proposed "Part 7 – Fire Services System Installation immediate after Break Tank" are considered to provide a guidance to the Industry on the selection and use of pipework, fittings and equipment in related to Fire Services System Installation such as Fire Hydrant / Hose reel system, Sprinkler system, Street Fire Hydrant system and automatic fixed installation using water system.

Hon. Technical Adviser
Mr Simon S.F. Tsang 曾兆輝

Hope the above could be discuss and review in coming legislation and amendment of the water regulation.

Co-opted Member
Mr King TK Cheng 鄭子勁
Mr Linus C.H. Hui 許志恆
Mr Y.K. Kwong 龔奕權
Mr W.Y. Lam 林永恩
Mr William P.W. Lee 李栢榮
Mr Terence W.K. Leong 梁偉強
Mr Eddie W.P. Leung 梁永沛
Mr W.K. Li 李偉球
Mr Raymond K.C. To 杜家駿
Mr Kenneth K. W. Wong 黃君華
Mr Wilson C.Y. Yau 邱子輝

We would be grateful if you could kindly consider our suggestion.

Yours truly,



Eric C.T. Yung
Chairman
The Association of Registered Fire Service
Installation Contractors of Hong Kong Limited