

Table 1: Summary of Indoor Pollutant Levels Recorded from the 40 Offices During The Summer Survey

Pollutant	IAQ-O	Unit	High	Low	Mean	SD	50 percentile	75 percentile	95 percentile
CO	10,000	$\mu\text{g}/\text{m}^3$	1958.91	233.02	854.25	456.57	744.12	1102.4	1809.78
CO ₂	1,000	ppm	1816.03	506.33	958.63	276.56	866.94	1082.74	1506.25
HCHO	100*	$\mu\text{g}/\text{m}^3$	176.98	20.86	71.28	41.70	63.92	105.52	132.24
NO ₂	150	$\mu\text{g}/\text{m}^3$	49.63	4.20	18.97	10.92	15.42	25.26	39.28
O ₃	120	$\mu\text{g}/\text{m}^3$	124.62	27.48	37.32	20.25	27.48	38.50	82.83
RSP	180	$\mu\text{g}/\text{m}^3$	163.57	6.75	29.74	24.15	24.04	34.97	51.64
Nicotine	6.8	$\mu\text{g}/\text{m}^3$	5.26	0.95	1.438	1.15	0.95	0.95	3.95
Benzene	16.1	$\mu\text{g}/\text{m}^3$	102.09	0.32	6.57	15.24	3.03	5.98	16.99
Carbon tetrachloride	103	$\mu\text{g}/\text{m}^3$	2.05	0.63	0.78	0.30	0.63	0.79	1.26
Chloroform	163	$\mu\text{g}/\text{m}^3$	2.43	0.21	0.52	0.51	0.28	0.57	1.78
o-dichlorobenzene	500	$\mu\text{g}/\text{m}^3$	4.21	0.60	1.08	0.75	0.75	1.20	2.65
m-dichlorobenzene	500	$\mu\text{g}/\text{m}^3$	22.70	0.60	2.79	4.27	0.80	3.00	11.91
p-dichlorobenzene	200	$\mu\text{g}/\text{m}^3$	72.45	0.60	14.03	16.84	6.77	14.13	51.59
Ethyl benzene	1,447	$\mu\text{g}/\text{m}^3$	455.22	0.43	20.45	70.11	3.58	9.45	85.08
Tetrachloroethylene	250	$\mu\text{g}/\text{m}^3$	15.95	0.68	2.95	3.41	1.53	3.06	10.19
Toluene	1,092	$\mu\text{g}/\text{m}^3$	3113.70	4.05	247.76	598.51	56.72	150.98	1294.40
Trichloroethylene	770	$\mu\text{g}/\text{m}^3$	995.00	0.54	29.15	149.13	1.21	3.23	42.68
o-xylene	1,447	$\mu\text{g}/\text{m}^3$	216.77	0.87	14.91	37.30	4.55	7.37	66.87
m,p-xylene	1,447	$\mu\text{g}/\text{m}^3$	586.36	0.43	35.91	94.97	9.97	16.80	167.35
Bacteria	1,000	cfu/m ³	2777.33	38.67	739.15	541.57	598.67	959.0	1680.33
Fungi	500	cfu/m ³	1414.67	13.5	186.88	270.96	86.17	194.67	482.47

Note :

* 30-minute average